



MTL66x DISPLAYS



 ϵ

- Loop powered 4-20mA
- Field and panel mounting
- **Environmental protection to** IP67 (IP65 panel mounted)
- Easy to configure

- Zone 0 or Zone 2 options
- **Number of displayed digits** configurable
- **Backlight options**

The MTL661, MTL662 and MTL663 digital indicators enable process variables to be displayed locally in hazardous and general purpose plant areas. A typical example would be the retransmission of mass/flow computations from the safe area, through a suitable MTL IS interface to the indicator in the hazardous area.

The displays are loop powered from the 4-20mA process signal and their low voltage drop allows them to be installed in almost any 2-wire, 4-20mA transmitter loop.

All units can indicate measured values in a linear or a square root extraction mode; the latter being used, for example, to display flow from differential pressure measurement devices such as orifice plates, Dall tubes, or venturi.

The MTL661 Field mounting unit is housed in a tough aluminium enclosure, suitable for wall or pipe mounting. For corrosive atmospheres use either the MTL661-ABS or MTL663 - their plastic cases provide excellent resistance to harmful contaminents. The MTL661-ABS can also be panel mounted by fixing the rear cover behind the panel with an additional gasket (GAS66).

MTL66x IS indicators are classified as 'nonenergy storing' simple apparatus so they can be inserted into any IS loop without recertification.

MTL661, MTL662 & MTL663 **ZONE 0 INDICATORS**

IS, loop powered + backlight 'B' option

 ϵ

The MTL66x range offers a variety of field and panel mounting IS indicators to display the current flowing in a 4-20mA loop. The small voltage drop of <1V allows the loop powered display to be installed in almost any 4-20mA loop.

Configuration is carried out using the front panel switches (which can be password protected). Range units, upper and lower limits, decimal point positioning and number of digits displayed are all configured via the front panel.



Unit location

Zone O, IIC, T4 hazardous area Div 1, Group A, hazardous location

Display

5½ digits - 26mm height (process value) Eleven 8mm digits (process units & current)

Voltage requirements under all conditions

<1V, loop powered

Ambient Temperature

-20°C to +70°C Operating: Storage: -40°C to +80°C **Humidity**

5-99%RH Input range

4-20mA

Over-range

200mA maximum without damage

Display Range

-99999 to 199999 (Configurable)

Number of digits after decimal point configurable

Zero and span

Setting: anywhere in range

Scale direction

Normal or reverse: software selected.

Out of range indication

"---- RANGE ERROR" displayed between 3.5 - 3.75mA "99999 RANGE ERROR" displayed at current >22mA

Operating modes

Linear or square root extraction is software selectable.

Accuracy at 20°C

 $\pm 0.01 mA$

Effects of temperature on accuracy

Zero: ± 0.0025% of span /°C Span: \pm 0.01% of span /°C

Ripple rejection

<0.01mA error with 1mA peak to peak ripple at 50Hz

Electrical safety

The input circuit of the indicator is designed such that it does not influence the intrinsically safe circuit to which it is connected. (In the USA the application is covered by the entity concept.)

Input circuit (terminals 4 & 5) in type of explosion protection intrinsically safe EEx ia IIC, with the following parameters: Ui=30V, Ii=200mA, Pi=1.2W, Ci=0nF, Li=0mH only for connection to a certified intrinsically safe circuit not exceeding these values.

Backlight (see Accessories for IS interfaces)

Separately powered backlight from an IS power source $(U_0 = 28V, I_0 = 200 \text{mA}, P_0 = 0.96W \text{ max.})$

Dimensions

See final page





APPROVALS

Country (Authority)	UK (ITS to CENELEC standards & ATEX Directive)		
Standards	EN 50014 : 1997 + A1, A2 EN 50281-1-1 : 1998 + A1 EN 50020 : 2002 EN 50284 : 1999		
Certificate/ file no.	KEMA 03 ATEX 1194X		
Approved for			

(The maximum temperature of the enclosure - T 100°C - is referred to an ambient temperature of 70°C and is applicable to a maximum dust layer thickness of 5mm.)

ORDERING INFORMATION

When ordering a MTL661, MTL662 or MTL663 for Zone O, use one of the following order codes to uniquely specify your requirement.

Order code	Туре	Backlight	Case material	Weight gms *	Case style
MTL661	Field	No	Aluminium	825	Α
MTL661B	Field	Yes	Aluminium	825	Α
MTL661-ABS	Field	No	ABS	375	С
MTL662	Panel	No	Aluminium	425	В
MTL662B	Panel	Yes	Aluminium	425	В
MTL663	Field	No	GRP	500	Α
MTL663B	Field	Yes	GRP	500	А

* nominal

MTL661 AND MTL662 **ZONE 2 INDICATORS**

non-arcing, loop powered

(E

The MTL661-NA (field mounting) and the MTL662-NA (panel mounting) are 4-20mA, loop-powered indicators for Zone 2 hazardous area operation. The small voltage drop of <1V allows the loop powered display to be installed in almost any 4-20mA loop.

Configuration is carried out using the front panel switches (which can be password protected). Range units, upper and lower limits, decimal point positioning and number of digits displayed are all configured via the front panel.



SPECIFICATION

Unit location

Zone 2, IIC, T4 hazardous area Div 2, Group A, hazardous location

Display

Six digits - 17mm height (process value) Eleven 8mm digits (process units & current)

Voltage requirements under all conditions

<1V, loop powered

Ambient Temperature

-20°C to +70°C Operating: Storage: -40°C to +80°C

Humidity 5-99%RH

Input range 4-20mA

Over-range

200mA maximum without damage

Display Range

-999999 to 999999 (Configurable)

Number of digits after decimal point configurable

Zero and span

Setting: anywhere in range

Scale direction

Normal or reverse: software selected.

Out of range indication

"---- RANGE ERROR" displayed between 3.5 - 3.75mA "999999 RANGE ERROR" displayed at current >22mA

Operating modes

Linear or square root extraction is software selectable.

Accuracy at 20°C

± 0.01mA

Effects of temperature on accuracy

Zero: \pm 0.0025% of span /°C Span: ± 0.01% of span /°C

Ripple rejection

<0.01mA error with 1mA peak to peak ripple at 50Hz

Dimensions

See final page

APPROVALS

Country (Authority)	UK (ITS to CENELEC standards & ATEX Directive)		
Standards	EN 50021:1999 EN 50281-1-1: 1998		
Certificate/ file no.	KEMA 03 ATEX 1509		
Approved for	 II 3 GD EEx nA II T4 T 80°C T_{amb} = −20°C to +70°C 		

(The maximum temperature of the enclosure - T 80°C - is referred to an ambient temperature of 70°C)

ORDERING INFORMATION

When ordering a MTL661 or MTL662 for Zone 2, use one of the following order codes to uniquely specify your requirement.

Order code	Туре	Backlight	Case material	Weight gms *	Case style
MTL661-NA†	Field	No	Aluminium	825	D
MTL662-NA†	Panel	No	Aluminium	425	Е

*nominal

† Delivered product will be labelled MTL661 or MTL662, as appropriate, and marked to indicate "Zone 2 use only".

ACCESSORIES

Order code	Description	Used with	
WMP66	Wall mounting plate	661/663	
PMA66	Pipe mounting adaptor	661/663	
PIP66-ABS	Pipe mounting kit	661-ABS	
PIP66	Pipe mounting kit	661-NA	
GAS66	Spare gaskets	661-NA, 661-ABS	
GAS660	Spare gaskets - pk of 10	661/663	

Recommended IS interfaces for powering display MTL5042, MTL4541, MTL7787+

Recommended IS interfaces for powering backlight MTL5021, MTL4521, MTL7728P+

EUROPE (EMEA) AMERICAS ASIA PACIFIC

 UROPE (EMEA)
 Tel: +44 (0)1582 723633
 Fax: +

 MERICAS
 Tel: +1 603 926 0090
 Fax: +

 SIAB PACIFIC
 Tel: +65 6 487 7887
 Fax: +

 -mail: enquiry@mt!-inst.com
 Web site: www.mt!-inst.com

Fax: +44 (0)1582 422283 Fax: +1 603 926 1899 Fax: +65 6 487 7997

Sept 2007



